SIEMENS

Data sheet

6GK1561-2AA00

product type designation



CP 5612

Communications processor CP 5612 PCI card for connection connection of a PG or PC with PCI bus to PROFIBUS or MPI usable in 32 bit and 64 bit operating systems see also entry ID 22611503.

transfer rate					
transfer rate					
 at the 1st interface / according to PROFIBUS 	9.6 kbit/s 12 Mbit/s				
interfaces					
number of electrical connections					
 at the 1st interface / according to PROFIBUS 	1				
type of electrical connection					
 at the 1st interface / according to PROFIBUS 	9-pin Sub-D socket (RS 485)				
 of the backplane bus 	PCI (32Bit 3,3V/5V UniversalKey 33/66MHz)				
supply voltage, current consumption, power loss					
type of voltage / of the supply voltage	DC				
supply voltage					
 1 / from backplane bus 	3.3 V				
• 2 / from backplane bus	12 V				
relative symmetrical tolerance / at DC					
• at 3.3 V	9 %				
• at 12 V	8 %				
consumed current					
 1 / from backplane bus / at DC / maximum 	0.15 A				
 2 / from backplane bus / at DC / maximum 	0.25 A				
power loss [W]	3.5 W				
ambient conditions					
ambient temperature					
 during operation 	5 55 °C				
 during storage 	-20 +60 °C				
 during transport 	-20 +60 °C				
relative humidity / at 25 °C / without condensation / during _operation / maximum	95 %				
protection class IP	IP00				
design, dimensions and weights					
module format	PCI				
width	18 mm				
height	107 mm				
depth	125 mm				
net weight	98 g				
product features, product functions, product components / general					
number of plug-in cards of same design / plug-in / per PC station	1				
number of units / note	-				

performance data / open communication					
software / for open communication / by means of SEND/RECEIVE / required	Yes, SOFTNET-PB DP / SOFTNET-PB DP Slave / SOFTNET-PB S7				
number of possible connections / for open communication / by means of SEND/RECEIVE / maximum	50				
performance data / PROFIBUS DP					
software / for DP master function / required	Yes, SOFTNET-PB DP				
service / as DP master					
• DPV0	Yes				
• DPV1	Yes				
• DPV2	No				
number of DP slaves / on DP master / operable	64				
data volume					
 of the address range of the inputs / as DP master / total 	14640 byte				
 of the address range of the outputs / as DP master / total 	14640 byte				
 of the address range of the inputs / per DP slave 	244 byte				
 of the address range of the outputs / per DP slave 	244 byte				
 of the address range of the diagnostic data / per DP slave 	244 byte				
software / for DP slave function / required	Yes, SOFTNET-PB DP slave				
service / as DP slave					
• DPV0	Yes				
• DPV1	No				
data volume					
• of the address range of the inputs / as DP slave / total	122 byte				
of the address range of the outputs / as DP slave / total	122 byte				
performance data / S7 communication					
software / for S7 communication / required	Yes, SOFTNET-PB S7				
number of possible connections / for S7/PG communication / maximum	8				
performance data / multi-protocol mode					
number of configurable connections / per PC station	207				
product functions / management, configuration, engineering					
configuration software / required	Included in the scope of delivery of the required software product				
product functions / diagnostics					
product function					
port diagnostics	Yes				
standards, specifications, approvals					
reference code	1/50				
according to IEC 81346-2:2019	KEC				
standards, specifications, approvals / Environmental Product De					
Environmental Product Declaration	Yes				
global warming potential [CO2 eq]					
• total	129.61 kg				
during manufacturing	33.23 kg				
during operation	96.32 kg				
after end of life	0.06 kg				
accessories	antional: MDL apple				
accessories	optional: MPI cable				
further information / internet links					
internet link	https://gupport.industry.gipmore.com/achanylachia.u/400700050				
to website: Selection guide for cables and connectors to web page: selection aid TIA Selection Teel	https://support.industry.siemens.com/cs/ww/en/view/109766358				
to web page: selection aid TIA Selection Tool to website: Industrial communication	https://www.siemens.com/tstcloud				
to website: Industrial communication	https://www.siemens.com/simatic-net				
to web page: SiePortal to website: Image database	https://sieportal.siemens.com/ https://www.automation.siemens.com/bilddb				
to website: Image database to website: CAx Deveload Manager					
to website: CAx-Download-Manager to website: Industry Online Support	https://www.siemens.com/cax				
to website: Industry Online Support	https://support.industry.siemens.com				
security information					
security information	Siemens provides products and solutions with industrial cybersecurity functions that support the secure operation of plants, systems, machines and networks. In order to protect plants, systems, machines and networks against cyber threats, it is necessary to implement – and continuously maintain – a holistic,				

state-of-the-art industrial cybersecurity concept. Siemens' products and solutions constitute one element of such a concept. Customers are responsible for preventing unauthorized access to their plants, systems, machines and networks. Such systems, machines and components should only be connected to an enterprise network or the internet if and to the extent such a connection is necessary and only when appropriate security measures (e.g. firewalls and/or network segmentation) are in place. For additional information on industrial cybersecurity measures that may be implemented, please visit www.siemens.com/cybersecurity-industry. Siemens' products and solutions undergo continuous development to make them more secure. Siemens strongly recommends that product updates are applied as soon as they are available and that the latest product versions are used. Use of product versions that are no longer supported, and failure to apply the latest updates may increase customer's exposure to cyber threats. To stay informed about product updates, subscribe to the Siemens.com/cert. (V4.7)

Approvals /	Certificates				
General F	roduct Approval			EMV	Environment
	on of Con- nity	CE EG-Konf.	RCM	KC	<u>Confirmation</u>

last modified:

8/8/2024 🖸