## **SIEMENS**

Data sheet 6GT2091-4LH20

product type designation

product description

## Cable RS422, Sub-D / M12

Highly flexible communication line (6-core)

SIMATIC RF, MV plug-in cable, pre-assembled, between RF120C and reader PUR, trailing, length 2 m.



suitability for use	Plug-in cable for connecting a reader to the RF120C communication module	
cable designation	L-YC11Y 6x1x0.25 6x24AWG CM	
wire length	2 m	
electrical data		
number of electrical connections	2	
type of electrical connection	Sub-D (male, 9 pin, 45°) / M12 (female, 8 pin, straight)	
loop resistance per length / maximum	160 mΩ/m	
insulation resistance coefficient	20 GΩ·m	
operating voltage		
• maximum	300 V	
nechanical data		
number of electrical cores	6	
design of the shield	Braided shield made of tin-plated copper wires	
outer diameter		
of cable sheath	5.4 mm	
symmetrical tolerance of the outer diameter / of cable sheath	0.2 mm	
material		
<ul> <li>of the wire insulation</li> </ul>	PVC	
of cable sheath	PUR	
color		
<ul> <li>of the insulation of data wires</li> </ul>	DIN 47100	
<ul> <li>of cable sheath</li> </ul>	Black	
bending radius		
<ul> <li>with single bend / minimum permissible</li> </ul>	21.6 mm	
<ul><li>with multiple bends / minimum permissible</li></ul>	43 mm	
<ul> <li>with continuous bending</li> </ul>	75 mm	
number of bending cycles	3000000	
tensile load / maximum	200 N	
weight per length	45 kg/km	
ambient conditions		
ambient temperature		
during operation	-30 +80 °C	
during storage	-30 +80 °C	
during transport	-30 +80 °C	
during installation	-30 +80 °C	
fire behavior	flame resistant according to IEC 60332-1-2	
class of burning behaviour / according to EN 13501-6	Eca	
chemical resistance		

As well-send all				
• to mineral oil	resistant			
to grease  radiological resistance / to UV radiation	resistant			
product features, product functions, product components / gene	resistant			
product feature				
halogen-free	No			
silicon-free	Yes			
standards, specifications, approvals	165			
UL/ETL listing / 300 V Rating	Yes; CM (only cable without plug)			
certificate of suitability	165, OW (Only cable without plug)			
EAC approval	Yes			
reference code	165			
according to IEC 81346-2	WG			
• according to IEC 81346-2:2019	WGB			
further information / internet links	Web			
internet link				
to website: Selection guide for cables and connectors	https://support.industry.siamans.com/cs/ww/an/view/10	0766358		
to website. Selection guide for cables and connectors     to web page: selection aid TIA Selection Tool	https://support.industry.siemens.com/cs/ww/en/view/109766358 https://www.siemens.com/tstcloud			
• to web page: Selection and TIA Selection Tool	https://sieportal.siemens.com/			
• to web page. Stell ortall • to website: Image database	https://www.automation.siemens.com/bilddb			
to website: Image database     to website: CAx-Download-Manager	https://www.siemens.com/cax			
to website: OAX-Download-Manager     to website: Industry Online Support	https://support.industry.siemens.com			
security information	Intps://support.industry.sichiciis.com			
Approvals / Certificates	that support the secure operation of plants, systems, machines and networks. In order to protect plants, systems, machines and networks against cyber threats, it is necessary to implement – and continuously maintain – a holistic, state-of-the-art industrial cybersecurity concept. Siemens' products and solutions constitute one element of such a concept. Customers are responsible for preventing unauthorized access to their plants, systems, machines and networks. Such systems, machines and components should only be connected to an enterprise network or the internet if and to the extent such a connection is necessary and only when appropriate security measures (e.g. firewalls and/or network segmentation) are in place. For additional information on industrial cybersecurity measures that may be implemented, please visit www.siemens.com/cybersecurity-industry. Siemens' products and solutions undergo continuous development to make them more secure. Siemens strongly recommends that product updates are applied as soon as they are available and that the latest product versions are used. Use of product versions that are no longer supported, and failure to apply the latest updates may increase customer's exposure to cyber threats. To stay informed about product updates, subscribe to the Siemens Industrial Cybersecurity RSS Feed under https://www.siemens.com/cert. (V4.7)			
General Product Approval		EMV		
CE UK CCC	EAC	<u>KC</u>		
Environment				
Confirmation				

last modified:

8/8/2024